



- LIGHTING PLAN KEY NOTES:**
- 1 SWITCH TO OPERATE WIBC DOOR LIGHTS VIA CONTACTOR.
 - 2 BALLAST TO OPERATE BELOW 40° F
 - 3 EXTEND WIRING CIRCUITS AT W.I.B.C. FOR LIGHTS, FRAME, DOOR HEATERS.
 - 4 CONNECT TO UN-SWITCHED LEG.
 - 5 LIGHTS SWITCHED IN PANEL TYPICAL.
 - 6 PADDLE FANS SWITCHED IN PANEL WITH LIGHTING PACKAGE.
 - 7 PADDLE FAN TO BE MTD. MIN. 8'-0" A.F.F.
 - 8 AUDIO SPEAKER; REFER TO SHT. E-1 FOR SPEC. TERMINATE SPEAKER WIRE IN STORAGE RM.
 - 9 PROVIDE SWITCH BANK AS INDICATED TO BE LOCATED NEAR MANAGER STAND.
 - 10 NIGHT LIGHT WITH EMERGENCY BALLAST.
 - 11 ELECTRICAL FAN - SEE M-1 FOR ADDITIONAL INFORMATION.
 - 12 OCCUPANCY SENSOR (WALL SWITCH WS1201)
 - 13 OCCUPANCY SENSOR (CEILING ATU1000C)

- LIGHTING PLAN GENERAL NOTES:**
- A SEAL OFF FITTINGS TO BE INSTALLED ON ALL RACEWAYS GOING TO THE WIBC AT TRANSITION FROM STORE TO COOLER.
 - B LIGHTING TO BE RELOCK OR EMT INSTALLATION.
 - C NL NIGHT LIGHT WITH EMERG. BALLAST
 - D EF EXHAUST FAN CONNECTED TO LIGHT
 - E GENERAL LIGHTING LOAD BRANCH CIRCUITRY TO HAVE NO MORE THAN 3 CIRCUITS PER HOME RUN.
 - F LIGHTING CONTACTORS SHALL BE REMOTELY CONTROLLED SUCH THAT EVERY OTHER ROW OF LIGHT FIXTURES IN THE SALES AREA SHALL BE ON SEPARATE CONTACTORS.
 - G LSI LIGHTING - ELECTRICAL CONDUIT / WIRING TO PENETRATE EXTERIOR WALL AND DROP DOWN TO BELOW ROOF ELEVATION.

1 LIGHTING PLAN
E-5 SCALE: 1/8" = 1'-0"

REVISIONS BY	
1	BUILDING DEPT. 5-14-08 S.L.M.
2	BUILDING DEPT. 9-2-08 S.L.M.

ALEX PIPER, P.E.
 CONSULTING ENGINEER, FL # 42697
 POWER • LIGHTING • SYSTEMS • DATA
 VOICE: 407-376-0648
 FAX: 407-376-3853
 100 W. Palm Dr., Leesburg, FL 34749
 ALEXPIPER@earthlink.net

ABC LIQUORS, INC.
 8989 S. ORANGE AVE. - ORLANDO, FLA. 32809
ABC STORE NO. 50
 SAWGRASS MILLS, SUNRISE, FLORIDA

DRAWN:	R. CARDONA
CHECKED:	S. RIVERA
DATE:	5-1-07
SCALE:	AS NOTED
JOB No:	50
SHEET	

E-3

LIGHTING PLAN