

## SECTION 10200

### LOUVERS AND VENTS

#### PART 1 - GENERAL

##### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

##### 1.2 SCOPE

- A. This section includes all exterior louvers located in masonry walls whether connected to ductwork and dampers or not. Furnish all labor, materials and related items for the complete fabrication, erection, weatherproofing and other miscellaneous work as required. Louvers required are indicated on the drawings.

##### 1.3 SUBMITTALS

- A. See Section 01300 - Submittals.

#### PART 2 - PRODUCTS

##### 2.1 INTERIOR DOOR GRILLES

- A. See Section 08211 - Flush Wood Doors.

##### 2.2 EXTERIOR GABLE/WALL LOUVERS

- A. Louvers shall be stationary type with "dual drain" blades contained within a single 4" flanged frame. Louver shall be equal to Construction Specialties Model A4157 AMCA Licensed, finished with baked acrylic enamel. Color will be selected by the Architect. Furnish 1/2" x 1/2" x 19 gauge galvanized steel bird screen within a removable frame on interior face of louver.

#### PART 3 - EXECUTION

##### 3.1 FABRICATION

- A. General: Shop-fabricate frames and bird screens into complete units, verifying all measurements at the job site prior to fabrication.
- B. Workmanship: Accurately miter and fit all members of hairline joints and weld.
- C. No discoloration on the face of any surface will be acceptable.

##### 3.2 SURFACE CONDITIONS

- A. Inspection: Prior to installation of the work of this section, carefully inspect the installed work of all other trades and verify that all such work is complete to the point where this installation may properly commence.

END OF SECTION