

---

**Dan Whalen**

**From:** Michael Albanese [MAlbanese@C4Architecture.com]  
**Sent:** Thursday, May 27, 2010 8:34 AM  
**To:** dwhalen@rdmichaels.com  
**Subject:** RE: Westminster Tower

Dan,

I can answer question no. 1 for you. I had to send out to the consultants an owner to get answers for questions 2-5. Hope to have answers for you by the end of the day or sooner.

For question no. 1, the top of slab at the 2<sup>nd</sup> floor is 14'-0" AFF. The concrete slab is 3" thick, thus top of bar joist at 13'-9". Bar joists run East to West and vary between 28" deep to 36" deep.

Thank you,  
Mike

Michael J. Albanese, RA, NCARB  
C4 Architecture  
4700 Millenia Blvd. Suite 390  
Orlando, Florida 32839  
tel - 407.363.6136  
fax - 407.363.6131  
malbanese@c4architecture.com